

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 02/05/26

This certificate is valid till 01/05/2027

Mr. Ramswaroop Ji
PHED, Mandore, Jodhpur.

Note: The certificate is to be issued by authorized officer/ PHED Lab / local bodies



OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT,
REGIONAL LABORATORY-JODHPUR (RAJ.)

Email:- phedregionallabjodhpur@gmail.com

No. Lab/Tech/Chm./2025-2026/ 595

Date : 20-02-2026

TEST REPORT OF THE CHEMICAL EXAMINATION OF WATER

To,

PRINCIPAL
THE UMMED SCHOOL
59/1 Opp.Mega Awas Yojna Near Mata ka than Surpura
JODHPUR

SAMPLE WAS NOT COLLECTED
BY THE LABORATORY

District: JODHPUR

Reference: 1483

Dated: 16.02.2026

Sample Taker: -

Date of Reciept	19.02.2026
Date of Collection	19.02.2026
Date of Examination	20.02.2026
Source Type	Tap Water
Source Location	Not for Legal Purpose 59/1 Opp.Mega Awas Yojna Near Mata ka than Surpura
City	JODHPUR
Lab Sample No.	PC-95

S. No.	Characteristics	Permissible Value as per BIS 10500/ 2012 Drinking Water Standards		Test Results
		Desirable Limit	Permissible Limit in absence of alternate Source	
1	pH @ 25 °C	6.5 to 8.5	No relaxation	7.53
2	Turbidity(NTU)	1	5	0.10
3	Colour	5	15	0.10
4	Odour	Agreeable	Agreeable	Agreeable
5	Temperature	---	---	-
6	Total Alkalinity (as CaCO ₃)	200	600	72
7	Total Hardness (as CaCO ₃)	200	600	100
8	Calcium (as Ca ⁺⁺)	75	200	30.40
9	Magnesium (as Mg ⁺⁺)	30	100	5.76
10	Chloride (as Cl ⁻)	250	1000	24
11	Sulphate(as SO ₄)	200	400	-
12	Nitrates (as NO ₃ ⁻)	45	No relaxation	3.90
13	Fluoride (as F ⁻)	1	1.5	0.10
14	Total Dissolved Solids (TDS)	500	2000	180

Remark:-

PRINCIPAL
THE UMMED SCHOOL
AFFILIATED TO CBSE
APPLICATION No.: 1730944

CHAIRMAN / MANAGER
THE UMMED SCHOOL
JODHPUR
Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur

No. Lab/Tech/Chm./2025-2026/

Date :

Copy to:

1. The Chief Chemist, Public Health Engineering Department-Rajasthan, Jaipur.

Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur